

Phone: +1 561 779 5660 - e-mail:datexel@datexel.com Web Site www.datexel.com



Isolated converter
RS232 ← →RS422

DAT 3580

#### **FEATURES**

- Asynchronous serial data transmission
- Automatic baud-rate fitting up to 115.2 Kbps
- Distance up to 1200 m
- Point to point connection or multi-point connection up to 32 modules
- DC or AC power supply
- Galvanic isolation on all ways
- RS232 connection on DB9 or removable terminals
- CE / UL / UKCA mark
- DIN rail mounting in compliance with EN-50022



## **GENERAL DESCRIPTION**

The device DAT3580 is an isolated interface converter between asynchronous serials lines RS232 and RS485 or RS422 that guarantees a full isolation between power supply, serial line RS-232 and serial line RS-485 or 422 removes eventual ground-loop effects, allowing the use of the device even in the heavy environmental conditions. It is designed to operate either on serial interface RS-422 full-duplex 4 wires or RS485 half-duplex 2 wires, with a baudrate transmission up to 115.2 Kbps. The transmission is asynchronous without settings of protocol, data format and baud rate.

On the line RS-232 are not necessary handshake commands (RTS, CTS, etc..) to control the baud rate.

The DAT 3580 is in compliance with the Directive UL 61010-1 for US market and with the Directive CSA C22.2 No 61010-1 for the Canadian market. The device is housed in a rough self-extinguishing plastic container which, thanks to its thin profile of 22.5 mm only, allows a high density mounting on EN-50022 standard DIN rail.

# **USER INSTRUCTIONS**

Before to install the device, please read the "Installation Instruction" section. The device converts the serial transmission from RS-232 to RS-485 (2 wires) or RS-422 (4 wires) as follows. The data incoming from the line TX of RS-232 (DB9 connector pin 3) are converted and transmitted to the terminals D-E of RS-485 and RS-422. The data incoming from the line RX of RS-485 (terminal D and E) or RS-422 (terminal B and C) are converted and transmitted to the terminal RX of RS-232 (DB9 connector pin 2).

The transmission of the signal follows the logic state of every single bit, then it is not necessary to set the protocol, the data format and the baud-rate. When the transmission line from the RS-232 is off, the RS-485 driver is in the receive condition (high impedance); when the transmission line from the RS-232 goes on, the RS-485 driver switch immediately to the transmission condition (low impedance). The low impedance is kept for about 150 us, then the line returns automatically in high impedance (receiver).

#### TECHNICAL SPECIFICATIONS (Typical @ 25 °C and in the nominal conditions)

TECHNICAL SPECIFIC	ATIONS (Typical @ 25 °C and	d in the nominal col	<u>iaitions)</u>		
RS-232		RS-485 / RS-422		GENERAL SPECIFICATIONS	
In compliance with st	andard EIA RS232	In compliance with	standard RS485 and RS422	Reverse polarity pro	oltage (UL) 10 30 Vdc otection 60 Vdc max oltage (UL) 9 18 Vac
Connection	DB9 /removable screw terminals	Baud-rate	up to 115.2 Kbps	optional: Max. Current cons	18 30 Vac umption 35 mA
		Cable Length	1200 m / 4000 ft max	ISOLATION	2000 Vac.
Cable Length	30 m / 100 ft max		m distance depends on the	Among all the ways	50 Hz, 1 min
		number of devices connected, on the type of cable used and its immunity against noises.		ENVIRONMENTAL Operative temperatu	
		Number of module	<b>s in multipoint</b> up to 32	UL Operative Temporature Storage temperature Humidity (not conde	e -40°C +85°C
		Switching time TX	<b>RX (RS485)</b> 150 us.	Maximum Altitude Installation Category of Installat	2000 m slm Indoor
			Internal terminator resistance (optional)		2
			120 Ohm	MECHANICAL SPE Material	CIFICATIONS Self-extinguish plastic
		Connection	removable screw terminals	IP Code Wiring	IP20 wires with diameter 0.8÷2.1 mm²
				Tightening Torque Mounting	AWG 14-18 0.5 N m in compliance with DIN rail standard EN-50022
				Weight	about 160 g.
					strial Environments )
				Immunity Emission	EN 61000-6-2 EN 61000-6-4
				UKCA (ref S.I. 2016 Immunity Emission UL	BS EN 61000-6-2 BS EN 61000-6-4
				US Standard Canadian Standard CCN	UL 61010-1 CSA C22.2 No 61010-1 NRAQ/NRAQ7
				Typology Classification File Number	Open Type device Industrial Control Equipment E352854

# **INSTALLATION INSTRUCTIONS**

The device is suitable for fitting to DIN rails in the vertical position.

For optimum operation and long life follow these instructions:

When the devices are installed side by side it may be necessary to separate them by at least 5 mm if panel temperature exceeds 45°C and high power supply value( > 27Vdc).

Make sure that sufficient air flow is provided for the device avoiding to place raceways or other objects which could obstruct the ventilation slits. Moreover it is suggested to avoid that devices are mounted above appliances generating heat; their ideal place should be in the lower part of the panel.

Install the device in a place without vibrations.

Moreover it is suggested to avoid routing conductors near power signal cables (motors, induction ovens, inverters, etc...) and to use shielded cable for connecting signals

RS-485
RS-422
POWER SUPPLY UNIT


RS-232
RS-232

## **LIGHT SIGNALLING**

LED	COLOUR	STATE	DESCRIPTION
PWR	GREEN	ON	Device powered
		OFF	Device not powered
TX	RED	FAST BLINK	Data transmitted from port RS232 (blink frequency depends to baud-rate)
	_	OFF	No communication in progress
RX	RED	FAST BLINK	Data received on port RS485/422 (blink frequency depends to baud-rate)
		OFF	No communication in progress



# MECHANICAL DIMENSIONS (mm)





The symbol reported on the product indicates that the product itself must not be considered as a domestic waste.

considered as a domestic waste.

It must be brought to the authorized recycle plant for the recycling of electrical and electronic waste.

For more information contact the proper office in the user's city , the service for the waste treatment or the supplier from which the product has been purchased.


## **WIRING**

# POWER SUPPLY (\*)




(\*) Note: for UL installation the device must be powered using a power supply unit classified NEC class 2 or SELV with limited energy

#### **RS232**



#### RS485



### RS422

